

(Christian County Water District) Water Quality Report (2020)

Water System ID: KY0240521 Manager: James Owen CCR Contact: James Owen

Phone: 270-886-3696

Mailing Address: P.O Box 7 Hopkinsville KY 42241

Meeting Location and Time: 1940 Dawson RD. Hopkinsville KY, 42240 1st Thursday Each Month at 6:00 pm

Source Information:

This report is to inform the public about the quality of water and service provided on a daily basis. During 2020 the Christian County Water District purchased water from three sources. Customers who live in the Gracey area Hwy 117, Hwy 272, Hwy 164, and all side roads in these areas were supplied with water purchased from Barkley Lake Water District which is treated surface water drawn from Barkley Lake. Customer who live on the Todd County side of west fork red river on Barkers Mill and Chapel Hill were supplied with surface water purchased from Todd County Water District all other customer in Christian County were supplied with water purchased from Hopkinsville Water Environment Authority (HWEA) has treated surface water which is drawn from Barkley Lake, the North Quarry and the South Quarry.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects may be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and may pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: Microbial contaminants, such as viruses and bacteria, (sewage plants, septic systems, livestock operations, or wildlife). Inorganic contaminants, such as salts and metals, (naturally occurring or from stormwater runoff, wastewater discharges, oil and gas production, mining, or farming). Pesticides and herbicides, (stormwater runoff, agriculture or residential uses). Organic chemical contaminants, including synthetic and volatile organic chemicals, (by-products of industrial processes and petroleum production, or from gas stations, stormwater runoff, or septic systems). Radioactive contaminants, (naturally occurring or from oil and gas production or mining activities). In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water to provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Information About Lead:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your local public water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Some or all of these definitions may be found in this report:

Maximum Contaminant Level (MCL) - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - the level of a drinking water disinfectant below which there is no known or expected risk to health.

MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Below Detection Levels (BDL) - laboratory analysis indicates that the contaminant is not present.

Not Applicable (N/A) - does not apply.

Parts per million (ppm) - or milligrams per liter, (mg/L). One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) - or micrograms per liter, (pg/L). One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Parts per quadrillion (ppq) - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

Picocuries per liter (pCi/L) - a measure of the radioactivity in water.

Millirems per year (mrem/yr) - measure of radiation absorbed by the body.

Million Fibers per Liter (MFL) - a measure of the presence of asbestos fibers that are longer than 10 micrometers.

Nephelometric Turbidity Unit (NTU) - a measure of the clarity of water. Turbidity has no health effects. However, turbidity can provide a medium for microbial growth. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system.

Variances & Exemptions (V&E) - State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system shall follow.

Treatment Technique (TT) - a required process intended to reduce the level of a contaminant in drinking water.

Spanish (Español) Este informe contiene información muy importante sobre la calidad de su agua beber. Tradúzcalo o bable con alguien que lo entienda bien.

Christian County Water District

Water Quality Data Table

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Halacetic Acids (HAA5) (PPb)	NA	60	28	17	40	2020	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes] (ppb)	NA	80	37	26	61	2020	No	By-product of drinking water disinfection
Microbiological Contaminants								
Total Coliform (RTCR)	NA	TT	NA	NA	NA	2020	No	Naturally present in the environment
Contaminants	MCLG	AL	Your Water	Sample Date	#Samples Exceeding AL	Exceeds AL	Typical Source	
Inorganic Contaminants								
Copper - action level at consumer taps (ppm)	1.3	13	.11	2018	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	
Inorganic Contaminants								
Lead - action level at consumer taps (ppb)	0	15	.002	2018	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	

Undetected Contaminants

The following contaminants were monitored for, but not detected, in your water.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Violation	Typical Source
Chlorine (as Cl ₂) (ppm)	4	4	1.12	No	Water additive used to control microbes

Unregulated Contaminants

Unregulated contaminants are those that don't yet have a drinking water standard set by the US Environmental Protection Agency. The purpose of monitoring for these contaminants is to help US EPA decide whether the contaminants should have a standard. This are the Range that were detected.

	Lowest	Highest
Butanol	ND	2.71
Methoxyethanol	ND	0.415
Manganese 55	ND	4.23
HAA5	17.1	72.2
HAA6	3.44	16.8
HAA9	20.5	88.2

2020 Water Quality Data

The data presented in this report is from the most recent testing done in accordance with administrative regulations in 401 KAR Chapter 8. As authorized and approved by the EPA, the State has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data in this table, though representative, may be more than one year old.

	Allowable Levels	Highest Single Level	Lowest Monthly %	Violation	Likely Source
1. Turbidity (NTU) TT	Never more than 1 NTU Less than 0.3 NTU 95% of samples each month. (Population >10,000)	0.09	100%	No	Soil runoff
Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration.					

Regulated Contaminant Test Results

Contaminant [code] (units)	MCL	MCLG	Report Level	Range	Date of Sample	Violation Yes/No	Likely Source of Contamination
Microbial Contaminants							
2. E. coli Bacteria 0% positive samples	0%	0	0%	N/A	N/A	No	Human and animal fecal waste
Radioactive Contaminants							
3. Combined Radium (pCi/L)	5	0	1.5	1.5 - 1.5	Feb 2017	No	Erosion of natural deposits
4. Uranium (ug/l)	30	0	2.2	2.2 - 2.2	Feb 2017	No	Erosion of natural deposits
Inorganic Contaminants							
5. Copper [1022] (ppm) (0 sites exceeded the AL)	AL= 1.3	1.3	0.0543 (90 th percentile)	0.0015 - 0.0849	July - Sept 2018	No	Corrosions of household plumbing systems
6. Lead [1030] (ppb) (1 site exceeded the AL)	AL= 15	0	2.0 (90 th percentile)	2.0 - 38	July - Sept 2018	No	Corrosion of household plumbing systems
Lead and Copper monitoring is done together during the months of July, August and September.							
7. Barium [1010] (ppm)	2.0	2.0	0.038	0.038 - 0.038	January 2020	No	Drilling wastes; metal refineries; erosion of natural deposits
8. Fluoride [1025] (ppm)	4.0	4.0	0.66	0.66 - 0.66	January 2020	No	Water additive which promotes strong teeth
9. Mercury [1035] (ppb)	2.0	2.0	0.20	0.20 - 0.20	January 2020	No	Erosion of natural deposits; refineries and factories; landfills; runoff from cropland
10. Nitrate [1040] (ppm)	10	10	2.72	0.671 - 2.72	January 2020	No	Fertilizer runoff; leaching from septic tanks; sewage; erosion of natural deposits
11. Nitrite [1041] (ppm)	1	1	0.2	0.2 - 0.2	January 2020	No	Fertilizer runoff; leaching from septic tanks; sewage; erosion of natural deposits

Contaminant	MCL	MCLG	Report Level	Range	Date of	Violation	Likely Source of
Synthetic Organic Contaminants including Pesticides and Herbicides							
11. Atrazine [2050] (ppb)	3.0	3.0	0.35	BDL - 0.52	July 2020	No	Runoff from herbicide used on row crops
Disinfectants/Disinfection Byproducts and Precursors							
12. Total Organic Carbon (ppm)	TT	N/A	2.18 (lowest average)	1.00 - 3.10 (monthly ratios*)	2020	No	Naturally present in environment
*Monthly ratio is the % TOC removal achieved to the % TOC removal required. Lowest annual average of the monthly ratios must be 1.00 or greater to meet the treatment technique.							
13. Chlorine (ppm)	MRDL = 4	MRDLG = 4	1.50 (highest average)	0.21 - 2.48	2020	No	Water additive used to control microbes
14. Haloacetic acids or HAA (ppb) (Stage 2) Individual Sites	60	N/A	25 (annual average)	12 - 29	2020	No	By-product of drinking water disinfection
15. Total Trihalomethanes or TTHM (ppb) (Stage 2) Individual Sites	80	N/A	34 (annual average)	18 - 41	2020	No	By-product of drinking water disinfection

	Average	Range of Detection
Fluoride (added for dental health)	0.7	0.56 - 0.90
Sodium (EPA guidance level = 20 mg/l)	4.5	4.25 - 4.70

Maximum Contaminant Levels (MCLs) are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

The data presented in this report are from the most recent testing done in accordance with administrative regulations in 401 KAR Chapter 8. As authorized and approved by EPA, the State has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data in this table, though representative, may be more than one year old. Copies of this report are available upon request by contacting our office during business hours.

Regulated Contaminant Test Results Barkley Lake Regional Water District

Contaminant [code] (units)	MCL	MCLG	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination
Inorganic Contaminants							
Barium [1010] (ppm)	2	2	0.032	0.032 to 0.032	Aug-20	No	Drilling wastes; metal refineries; erosion of natural deposits
Fluoride [1025] (ppm)	4	4	0.76	0.76 to 0.76	Aug-20	No	Water additive which promotes strong teeth
Nitrate [1040] (ppm)	10	10	0.617	0.2 to 0.617	Feb-20	No	Fertilizer runoff; leaching from septic tanks, sewage; erosion of natural deposits
Nitrite [1041] (ppm)	1	1	0.2	0.2 to 0.2	Feb-20	No	Fertilizer runoff; leaching from septic tanks, sewage; erosion of natural deposits
Disinfectants/Disinfection Byproducts and Precursors							
Total Organic Carbon (ppm) (measured as ppm, but reported as a ratio)	T1*	N/A	1.81 (lowest average)	1.20 to 2.92 (monthly ratios)	2020	No	Naturally present in environment.
*Monthly ratio is the % TOC removal achieved to the % TOC removal required. Annual average must be 1.00 or greater for compliance.							
Chlorine (ppm)	MRDL ~ 4	MRDLG ~ 4	1.47 (highest average)	0.57 to 2.2 7	2020	No	Water additive used to control microbes.
HAA (ppb) (Stage 2) [Halocetic acids]	60	N/A	32 (high site average)	9 to 51 (range of individual sites)	2020	No	Byproduct of drinking water disinfection
THM (ppb) (Stage 2) [total trihalomethanes]	80	N/A	48 (high site average)	15 to 76 (range of individual sites)	2020	No	Byproduct of drinking water disinfection.
Household Plumbing Contaminants							
Copper [1022] (ppm) sites exceeding action level 0	AL - 1.3	1.3	0.564 (90 th percentile)	0.0086 to 0.775	Sep-20	No	Corrosion of household plumbing systems
Other Constituents							
Turbidity (NTU) TT * Representative samples	Allowable Levels	Highest Single Measurement	Lowest Monthly %	Violation	Likely Source of Turbidity		
Turbidity is a measure of the clarity of the water and not a contaminant.	No more than 1 NTU* Less than 0.3 NTU in 95% of monthly samples	0.15	100	No	Soil runoff		

This report will not be sent out to individual customers.

Logan/Todd Regional Water Commission 2020 Water Quality Data

The data presented in this report are from the most recent testing done in accordance with administrative regulations in 401 KAR Chapter 8. As authorized and approved by EPA, the State has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data in this table, though representative, may be more than one year old. Unless otherwise noted, the report level is the highest level detected.

	Allowable Levels	Highest Single Measurement	Lowest Monthly %	Violation	Likely Source
Turbidity (NTU) TT * Representative samples of filtered water	No more than 1 NTU* Less than 0.3 NTU in 95% of monthly samples	0.079	100	No	Soil runoff

Regulated Contaminant Test Results

Contaminant (code) (units)	MCL	MCLG	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination
Inorganic Contaminants							
Barium (ppm)	2	2	0.0182	0.0182 to 0.0182	Jun-20	No	Drilling wastes; metal refineries; erosion of natural deposits.
Fluoride (ppm)	4	4	0.686	0.686 to 0.686	Jun-20	No	Water additive which promotes strong teeth.
Nitrate (ppm)	10	10	0.579	0.579 to 0.579	Feb-20	No	Fertilizer runoff; leaching from septic tanks, sewage; erosion of natural deposits.

Disinfection/Disinfection Byproducts and Precursors

Total Organic Carbon (ppm) (measured as ppm, but reported as a ratio)	TT*	N/A	1.74 (lowest average)	1.73 to 1.98	2020	No	Naturally present in environment.
*Monthly ratio is the % TOC removal achieved to the % TOC removal required. Annual average of the monthly ratios must be 1.00 or greater for compliance.							

Chlorine (ppm)	MRDL = 4	MRDLG = 4	2.20 (highest average)	1.6 to 2.83	2020	No	Water additive used to control microbes.
HAA (ppb) (Stage 2) [Haloacetic acids] (Annual Sample)	60	N/A	31 (high site)	31 to 31	2020	No	Byproduct of drinking water disinfection.
THM (ppb) (Stage 2) [Total trihalomethanes] (Annual Sample)	80	N/A	60 (high site)	60 to 60	2020	No	Byproduct of drinking water disinfection.

Some or all of these definitions may be found in this report:

Maximum Contaminant Level (MCL) - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Not Applicable (N/A) - does not apply.

Parts per million (ppm) - or milligrams per liter, (mg/l). One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) - or micrograms per liter, (µg/L). One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Parts per quadrillion (ppq) - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

Picouries per liter (pCi/L) - a measure of the radioactivity in water.

Nephelometric Turbidity Unit (NTU) - a measure of the clarity of water. Turbidity has no health effects. However, turbidity can provide a medium for microbial growth. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system.

Treatment Technique (TT) - a required process intended to reduce the level of a contaminant in drinking water.

